

VOC Emission Test Certificate

Thursday 26th August 2021

Supplier: SaveBoard (NZ) Limited (17B Manukaka Heights, Hurdon, New Plymouth, 4310, New Zealand)

Sample Description: SaveBOARD Roofing Substrate / Rigid Air Barrier Board Product

Date Tested: August 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days):

<p align="center">Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">SaveBOARD Roofing Substrate / RAB Board</p>
<p>Total Volatile Organic Compounds Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compounds Rate: <0.003 mg/m²/hr</p>
<p>Formaldehyde Emission Rate Limit: ≤0.100 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.013 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
Ph.D, B.Eng. (Chemical)
Senior Consultant

V2108021